TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-24-01** **Date: 20-03-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements and Construction of CC Road and Drainage Work Bhuvaneshwari Nagara 1st Main road & 1st, 2nd, 3rd & 4th cross road & Muneshwar Badavane Shivarj house Road & Back side Of the Market Road at Ward No.15 Dasarahalli. (2nd Call)

Customer's Reference : EE/DD/WO/113/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 24-02-17

Sample ID No : 2017-02-24-01/02

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 28

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 18/03/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Road	M30	18/02/2017	18/03/2017	150.22 X 150.76 X 150.72	22647	8.098	772.3	34.1	33.7
2	Cement Concrete Road	M30	18/02/2017	18/03/2017	150.66 X 150.27 X 150.77	22640	8.187	760.7	33.6	
3	Cement Concrete Road	M30	18/02/2017	18/03/2017	149.18 X 150.76 X 150.22	22490	8.154	748.9	33.3	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-24-02** **Date: 20-03-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements and Construction of CC Road and Drainage Work Bhuvaneshwari Nagara 1st Main road & 1st, 2nd, 3rd & 4th cross road & Muneshwar Badavane Shivarj house Road & Back side Of the Market Road at Ward No.15 Dasarahalli. (2nd Call)

Customer's Reference : EE/DD/WO/113/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 24-02-17

Sample ID No : 2017-02-24-02/02

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 28

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 19/03/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm^2)	(N/mm^2)
1	Cement Concrete Road	M30	19/02/2017	19/03/2017	150.22 X 150.12 X 150.87	22551	8.098	771.2	34.2	33.6
2	Cement Concrete Road	M30	19/02/2017	19/03/2017	151.97 X 150.11 X 149.98	22812	8.017	750.5	32.9	
3	Cement Concrete Road	M30	19/02/2017	19/03/2017	149.51 X 150.65 X 150.22	22524	8.176	759.0	33.7	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ದಾಸರಹಳ್ಳಿ ಉಪವಿಭಾಗ
ಬೆಂಗಳೂರು ಪೂರ್ವ ವಿಭಾಗ
ಬೆಂಗಳೂರು

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-27-01** **Date: 20-03-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements and Construction of CC Road and Drainage Work Bhuvaneshwari Nagara 1st Main road & 1st, 2nd, 3rd & 4th cross road & Muneshwar Badavane Shivarj house Road & Back side Of the Market Road at Ward No.15 Dasarahalli. (2nd Call)

Customer's Reference : EE/DD/WO/113/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 27-02-17

Sample ID No : 2017-02-27-01/02

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 28

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 20/03/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm^2)	(N/mm^2)
1	Cement Concrete Road	M30	20/02/2017	20/03/2017	149.87 X 149.28 X 149.99	22373	8.176	758.4	33.9	33.4
2	Cement Concrete Road	M30	20/02/2017	20/03/2017	151.52 X 150.16 X 150.22	22752	8.175	757.6	33.3	
3	Cement Concrete Road	M30	20/02/2017	20/03/2017	150.26 X 150.98 X 150.87	22686	8.179	750.9	33.1	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬೆಂಗಳೂರು ದಾಸರಹಳ್ಳಿ
ಬೆಂಗಳೂರು

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-27-02** **Date: 21-03-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements and Construction of CC Road and Drainage Work Bhuvaneshwari Nagara 1st Main road & 1st, 2nd, 3rd & 4th cross road & Muneshwar Badavane Shivarj house Road & Back side Of the Market Road at Ward No.15 Dasarahalli. (2nd Call)

Customer's Reference : EE/DD/WO/113/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 27-02-17

Sample ID No : 2017-02-27-02/02

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 28

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 21/03/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm^2)	(N/mm^2)
1	Cement Concrete Road	M30	21/02/2017	21/03/2017	148.71 X 151.37 X 150.10	22510	8.187	769.8	34.2	33.4
2	Cement Concrete Road	M30	21/02/2017	21/03/2017	150.75 X 150.88 X 149.90	22745	8.081	752.9	33.1	
3	Cement Concrete Road	M30	21/02/2017	21/03/2017	150.27 X 150.11 X 150.21	22557	8.175	744.4	33.0	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರ ಕಛೇರಿ
ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-28-01** **Date: 23-03-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements and Construction of CC Road and Drainage Work Bhuvaneshwari Nagara 1st Main road & 1st, 2nd, 3rd & 4th cross road & Muneshwar Badavane Shivarj house Road & Back side Of the Market Road at Ward No.15 Dasarahalli. (2nd Call)

Customer's Reference : EE/DD/WO/113/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 28-02-17

Sample ID No : 2017-02-28-01/02

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 28

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 22/03/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Road	M30	22/02/2017	22/03/2017	149.65 X 150.87 X 150.08	22578	8.115	740.5	32.8	33.9
2	Cement Concrete Road	M30	22/02/2017	22/03/2017	150.21 X 150.65 X 150.64	22629	8.16	785.2	34.7	
3	Cement Concrete Road	M30	22/02/2017	22/03/2017	150.26 X 150.97 X 150.92	22685	8.175	773.6	34.1	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |